



Shawnee First Christian
Elevator Addition
Dated December 3, 2010

Addendum #2
1 Page

January 4, 2011

Revision: Specification Section 101436-Signage, Section A: Delete Interior Signage section A, specifically Part 2.1 & 2.2.

Addition: Sheet A3.1 Floor Plan: Add 4" wide Expansion Joint Cover at expansion joint between new addition & existing building.

Revision: Specification Section 142400, Hydraulic Elevators, Part 2.02, D: Carpet by owner.

Clarification: Sheet 1/A7.1 Room Finish Schedule: All four walls of Restroom 104 shall have tile wainscot to 4'-8" aff.

Addition: The following manufacturers/products have been added to the approved equal list for this project:
Otis Elevator Company

End of Addendum #2